SECTION 1

New York State Department of Enviromental Conservation
Division of Water

5W

Report Noncompliance Event

To: DEC Water Contact: Val Murakami DEC Region: 7

Report Type: _____ 5 day ___ Permit Violation _____ Order Violation _____ Anticipated Noncompliance __X__ Bypass/Overflow Other

SECTION 2

SPDES #: NY-- 0029106 **Facility:** Westside Wastewater Treatment Plant

Date of noncompliance: 7/17/21 **Location (Outfall, Treatment Unit, or Pump Station):** Outfall WWTP-SSO #004

Description of noncompliance(s) and cause(s): Bypass of sanitary sewer wastewater occured through unpermitted Outfall #004 due to high flows caused by heavy steady rain. Reported flow does not reflect what left our plant. Gardenier Creek was backing up into our flow chamber affecting the reading.

Has event ceased? (Yes)(No) **If so, when?** 7/18/21 **Was event due to plant upset?** (Yes) (No) **SPDES limits violation** (Yes) (No)

Start date, time of event: 7/17/21 , 11:25 (AM)(PM) End date, time of event: 7/18/21 12:00 (AM)(PM)

Date, time oral notification made to DEC? 7/18/21 (1:54 (AM)(PM) **DEC Official contacted:** Val Murakami

Immediate corrective actions: All wet weather procedures have been implented.

Preventive (long term) corrective actions:

SECTION 3

Complete this section if event was a bypass:

Bypass amount: 88,000 gals Was proir DEC authorization received for this event? (Yes)(No)

DEC Official contacted: _____ Date of DEC approval _____

Describe event in "Description of noncompliance and cause" area in Section 2. Detail the start and end dates and times in Section 2 also.

SECTION 4

Forms by EnviroWin (312-244-1900)

Facility Representative John McGrath **Title:** Chief Operator **Date:** 7/19/21

Phone #: 315 342-3777 **Fax #** 315 342-8233

3506-101 (12/93)

Signature: John W. McGrath