SECTION 1

New York State Department of Enviromental Conservation
Division of Water

8W

Report Noncompliance Event

To: DEC Water Contact: Valarie D. Ellis, P.E. DEC Region: 7

Report Type: _____ 5 day ____ Permit Violation _____ Order Violation _____ Anticipated Noncompliance X Bypass/Overflow Other

SECTION 2

SPDES #: NY-- 0029106 **Facility:** Westside Wastewater Treatment Plant

Date of noncompliance: 9/27/22 **Location (Outfall, Treatment Unit, or Pump Station):** Outfall WWTP-SSO #004

Description of noncompliance(s) and cause(s): Bypass of sanitary sewer wastewater occured through unpermitted Outfall #004 due to an extremely heavy wet weather event. Flow was observed coming in from the storm system. Then neither system was flowing. Both maxed out. This is a summary of two events. 9/27/22 11:18AM-5:35PM flow 2.72 MGD and 9/27/22 8:47 PM -9/28/22 9:05 AM Flow 3.89 MGD

Has event ceased? (Yes)(No) **If so, when?** 9/28/22 **Was event due to plant upset?** (Yes) (No) **SPDES limits violation** (Yes) (No)

Start date, time of event: 9/27/22 , 11:18 (AM)(PM) **End date, time of event:** 9/28/22 9:05 (AM)(PM)

Date, time oral notification made to DEC? 9/27/22 1:08 (AM)(PM) **DEC Official contacted:** Valarie Ellis

Immediate corrective actions: All wet weather procedures were implemented.

Preventive (long term) corrective actions:

SECTION 3

Complete this section if event was a bypass:

Bypass amount: 6,920,000 gals **Was proir DEC authorization received for this event?** (Yes)(No)

DEC Official contacted: _____ **Date of DEC approval** _____

Describe event in "Description of noncompliance and cause" area in Section 2. Detail the start and end dates and times in Section 2 also.

SECTION 4

Forms by EnviroWin (312-244-1900)

Facility Representative Dan Ramer **Title:** Chief Operator **Date:** 9/28/22

Phone #: 315 342-3777 **Fax #** 315 342-8233

3506-101 (12/93)

Signature: Dan Ramer